



88 Empire Drive • St. Paul, Minnesota • 55103
 (651) 642-1150 • fax (651) 642-1239

VOC Content Test Certificate

June 28, 2013

Supplier: Hilti Entwicklungsgesellschaft mbH
 BU Anchors
 Hiltistrasse 6
 86916 Kaufering
 GERMANY

Sample Description: Hilti Collar Endless CFS-C EL

Date Tested: May 17, 2013

Test Method: SCAQMD method 304-91 "Determination of Volatile Organic Compounds (VOC) in Various Materials" as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168. The values also comply with the requirements of EPA test method #24.

Test Data:

Specification	Product
LEED 2009 (LEED 3.0) LEED 2.2 IEQ-4.1: Low-Emitting Materials – Adhesives and Sealants	Collar Endless CFS-C EL
Green Building Council of Australia Green Star Office Design 3.0, IEQ-13 Green Star Office Design 2.0, IEQ-13 Green Star Office Interiors 1.1, IEQ-11	
Architectural Sealant; VOC Limit: 250 g/L	Product contains: 11 g/L of VOC

Tom Barrett
 Vice President/Strategic Analytical Services

Scott Creekmur
 Chemist II